

**Industrial communication networks - Fieldbus
specifications - Part 4-12: Data-link layer protocol
specification - Type 12 elements**

This document is a preview generated by EVS

EESTI STANDARDI EESSÕNA

NATIONAL FOREWORD

See Eesti standard EVS-EN 61158-4-12:2014 sisaldab Euroopa standardi EN 61158-4-12:2014 inglisekeelset teksti.	This Estonian standard EVS-EN 61158-4-12:2014 consists of the English text of the European standard EN 61158-4-12:2014.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 31.10.2014.	Date of Availability of the European standard is 31.10.2014.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile standardiosakond@evs.ee.

ICS 25.040.40, 35.100.20, 35.110

Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:
Aru 10, 10317 Tallinn, Eesti; www.evs.ee; telefon 605 5050; e-post info@evs.ee

The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:
Aru 10, 10317 Tallinn, Estonia; www.evs.ee; phone 605 5050; e-mail info@evs.ee

EUROPEAN STANDARD

EN 61158-4-12

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2014

ICS 25.040.40; 35.100.20; 35.110

Supersedes EN 61158-4-12:2012

English Version

**Industrial communication networks - Fieldbus specifications -
Part 4-12: Data-link layer protocol specification - Type 12
elements
(IEC 61158-4-12:2014)**

Réseaux de communication industriels - Spécifications des
bus de terrain - Partie 4-12: Spécification du protocole de la
couche liaison de données - Éléments de type 12
(CEI 61158-4-12:2014)

Industrielle Kommunikationsnetze - Feldbusse - Teil 4-12:
Protokollspezifikation des Data Link Layer
(Sicherheitsschicht) - Typ 12-Elemente
(IEC 61158-4-12:2014)

This European Standard was approved by CENELEC on 2014-09-19. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65C/762/FDIS, future edition 3 of IEC 61158-4-12, prepared by SC 65C "Industrial networks" of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 61158-4-12:2014.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2015-06-19
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2017-09-19

This document supersedes EN 61158-4-12 :2012.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

This document has been prepared under a mandate given to CENELEC by the European Commission and the European Free Trade Association.

Endorsement notice

The text of the International Standard IEC 61158-4-12:2014 was approved by CENELEC as a European Standard without any modification.

In the official version, for bibliography, the following notes have to be added for the standards indicated:

IEC 61131-2	NOTE	Harmonised as EN 61131-2
IEC 61131-3	NOTE	Harmonised as EN 61131-3
IEC 61158-1:2014	NOTE	Harmonised as EN 61158-1:2014
IEC 61158-2:2014	NOTE	Harmonised as EN 61158-2:2014
IEC 61158-5-12:2014	NOTE	Harmonised as EN 61158-5-12:2014
IEC 61158-6-12	NOTE	Harmonised as EN 61158-6-12
IEC 61784-1	NOTE	Harmonised as EN 61784-1
IEC 61784-2	NOTE	Harmonised as EN 61784-2

Annex ZA
(normative)

**Normative references to international publications
with their corresponding European publications**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE 1 When an International Publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

NOTE 2 Up-to-date information on the latest versions of the European Standards listed in this annex is available here: www.cenelec.eu.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158-3-12	-	Industrial communication networks - Fieldbus specifications Part 3-12: Data-link layer service definition - Type 12 elements	EN 61158-3-12	-
IEC 61588	-	Precision clock synchronization protocol for - networked measurement and control systems	-	-
ISO/IEC 7498-1	-	Information technology - Open Systems Interconnection - Basic reference model: The basic model	-	-
ISO/IEC 7498-3	-	Information technology - Open Systems Interconnection - Basic reference model: Naming and addressing	-	-
ISO/IEC 8802-3	2000	Information technology - Telecommunications and information exchange between systems - Local and metropolitan area networks - Specific requirements Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications	-	-
ISO/IEC 9899	-	Information technology - Programming languages - C	-	-
ISO/IEC 10731	-	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-
IEEE 802.1Q	-	IEEE Standard for Local and metropolitan area networks - Media Access Control (MAC) Bridges and Virtual Bridges	-	-
IETF RFC 768	-	User Datagram Protocol	-	-
IETF RFC 791	-	Internet Protocol - DARPA Internet Program - Protocol Specification	-	-

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	9
1 Scope.....	10
1.1 General.....	10
1.2 Specifications.....	10
1.3 Procedures.....	10
1.4 Applicability.....	10
1.5 Conformance.....	10
2 Normative references.....	11
3 Terms, definitions, symbols, abbreviations and conventions.....	11
3.1 Reference model terms and definitions.....	11
3.2 Service convention terms and definitions.....	12
3.3 Common terms and definitions.....	13
3.4 Additional Type 12 definitions.....	13
3.5 Common symbols and abbreviations.....	16
3.6 Additional Type 12 symbols and abbreviations.....	17
3.7 Conventions.....	18
4 Overview of the DL-protocol.....	23
4.1 Operating principle.....	23
4.2 Topology.....	23
4.3 Frame processing principles.....	23
4.4 Data-link layer overview.....	24
4.5 Error detection overview.....	25
4.6 Node reference model.....	25
4.7 Operation overview.....	26
5 Frame structure.....	27
5.1 Frame coding principles.....	27
5.2 Data types and encoding rules.....	27
5.3 DLPDU structure.....	29
5.4 Type 12 DLPDU structure.....	32
5.5 Network variable structure.....	48
5.6 Type 12 mailbox structure.....	48
6 Attributes.....	50
6.1 Management.....	50
6.2 Statistics.....	65
6.3 Watchdogs.....	68
6.4 Slave information interface.....	71
6.5 Media independent interface (MII).....	75
6.6 Fieldbus memory management unit (FMMU).....	79
6.7 Sync manager.....	82
6.8 Distributed clock.....	89
7 DL-user memory.....	93
7.1 Overview.....	93
7.2 Mailbox access type.....	94
7.3 Buffered access type.....	96

8	Type 12: FDL protocol state machines.....	97
8.1	Overview of slave DL state machines	97
8.2	State machine description	98
Annex A (informative) Type 12: Additional specifications on DL-Protocol state machines.....		106
A.1	DHSM	106
A.2	SYSM.....	124
A.3	RMSM.....	136
Bibliography.....		140
Figure 1 – Type description example		19
Figure 2 – Common structure of specific fields.....		20
Figure 3 – Frame structure.....		24
Figure 4 – Mapping of data in a frame.....		25
Figure 5 – Slave node reference model.....		26
Figure 6 – Type 12 PDUs embedded in Ethernet frame.....		27
Figure 7 – Type 12 PDUs embedded in UDP/IP		27
Figure 8 – DL information type description		52
Figure 9 – Address type description		54
Figure 10 – DL control type description.....		55
Figure 11 – DL status type description		58
Figure 12 – Successful write sequence to DL-user control register		59
Figure 13 – Successful read sequence to the DL-user status register		60
Figure 14 – RX error counter type description		66
Figure 15 – Lost link counter type description		67
Figure 16 – Additional counter type description.....		68
Figure 17 – Watchdog divider type description.....		68
Figure 18 – DLS-user Watchdog divider type description		69
Figure 19 – Sync manager watchdog type description.....		69
Figure 20 – Sync manager watchdog status type description		70
Figure 21 – Watchdog counter type description.....		71
Figure 22 – Slave information interface access type description		71
Figure 23 – Slave information interface control/status type description		73
Figure 24 – Slave information interface address type description		74
Figure 25 – Slave information interface data type description		75
Figure 26 – MII control/status type description		76
Figure 27 – MII address type description		78
Figure 28 – MII data type description		78
Figure 29 – MII access type description		79
Figure 30 – FMMU mapping example		80
Figure 31 – FMMU entity type description		81
Figure 32 – SyncM mailbox interaction.....		83
Figure 33 – SyncM buffer allocation		83
Figure 34 – SyncM buffer interaction		84

Figure 35 – Handling of write/read toggle with read mailbox	85
Figure 36 – Sync manager channel type description	87
Figure 37 – Distributed clock local time parameter type description	91
Figure 38 – Successful write sequence to mailbox	94
Figure 39 – Bad write sequence to mailbox.....	95
Figure 40 – Successful read sequence to mailbox.....	95
Figure 41 – Bad read sequence to mailbox	96
Figure 42 – Successful write sequence to buffer	96
Figure 43 – Successful read sequence to buffer.....	97
Figure 44 – Structuring of the protocol machines of an slave	98
Figure 45 – Slave information interface read operation	100
Figure 46 – Slave information interface write operation.....	101
Figure 47 – Slave information interface reload operation	102
Figure 48 – Distributed clock	104
Figure 49 – Delay measurement sequence	105
Table 1 – PDU element description example.....	19
Table 2 – Example attribute description	20
Table 3 – State machine description elements	22
Table 4 – Description of state machine elements	22
Table 5 – Conventions used in state machines	22
Table 6 – Transfer Syntax for bit sequences	28
Table 7 – Transfer syntax for data type Unsignedn	28
Table 8 – Transfer syntax for data type Integern	29
Table 9 – Type 12 frame inside an Ethernet frame	30
Table 10 – Type 12 frame inside an UDP PDU.....	30
Table 11 – Type 12 frame structure containing Type 12 PDUs	31
Table 12 – Type 12 frame structure containing network variables	31
Table 13 – Type 12 frame structure containing mailbox	32
Table 14 – Auto increment physical read (APRD).....	32
Table 15 – Configured address physical read (FPRD).....	33
Table 16 – Broadcast read (BRD)	35
Table 17 – Logical read (LRD)	36
Table 18 – Auto Increment physical write (APWR)	37
Table 19 – Configured address physical write (FPWR).....	38
Table 20 – Broadcast write (BWR)	39
Table 21 – Logical write (LWR).....	40
Table 22 – Auto increment physical read write (APRW)	41
Table 23 – Configured address physical read write (FPRW).....	42
Table 24 – Broadcast read write (BRW)	44
Table 25 – Logical read write (LRW)	45
Table 26 – Auto increment physical read multiple write (ARMW).....	46
Table 27 – Configured address physical read multiple write (FRMW)	47

Table 28 – Network variable	48
Table 29 – Mailbox	49
Table 30 – Error Reply Service Data	49
Table 31 – DL information	52
Table 32 – Configured station address	54
Table 33 – DL control	55
Table 34 – DL status	58
Table 35 – DLS-user specific registers	60
Table 36 – DLS-user event	62
Table 37 – DLS-user event mask	63
Table 38 – External event	64
Table 39 – External event mask	65
Table 40 – RX error counter	66
Table 41 – Lost link counter	67
Table 42 – Additional counter	68
Table 43 – Watchdog divider	69
Table 44 – DLS-user watchdog	69
Table 45 – Sync manager channel watchdog	70
Table 46 – Sync manager watchdog Status	70
Table 47 – Watchdog counter	71
Table 48 – Slave information interface access	71
Table 49 – Slave information interface control/status	73
Table 50 – Actual slave information interface address	75
Table 51 – Actual slave information interface data	75
Table 52 – MII control/status	76
Table 53 – Actual MII address	78
Table 54 – Actual MII data	78
Table 55 – MII access	79
Table 56 – Fieldbus memory management unit (FMMU) entity	81
Table 57 – Fieldbus memory management unit (FMMU)	82
Table 58 – Sync manager channel	87
Table 59 – Sync manager Structure	89
Table 60 – Distributed clock local time parameter	91
Table 61 – Distributed clock DLS-user parameter	93
Table A.1 – Primitives issued by DHSM to PSM	106
Table A.2 – Primitives issued by PSM to DHSM	106
Table A.3 – Parameters used with primitives exchanged between DHSM and PSM	106
Table A.4 – Identifier for the octets of a Ethernet frame	107
Table A.5 – DHSM state table	109
Table A.6 – DHSM function table	124
Table A.7 – Primitives issued by SYSM to DHSM	124
Table A.8 – Primitives issued by DHSM to SYSM	125
Table A.9 – Primitives issued by DL-User to SYSM	125

Table A.10 – Primitives issued by SYSM to DL-User.....	125
Table A.11 – Parameters used with primitives exchanged between SYSM and DHSM	125
Table A.12 – SYSM state table	127
Table A.13 – SYSM function table.....	136
Table A.14 – Primitives issued by RMSM to SYSM	136
Table A.15 – Primitives issued by SYSM to RMSM	137
Table A.16 – Parameters used with primitives exchanged between RMSM and SYSM	137
Table A.17 – RMSM state table.....	138
Table A.18 – RMSM function table	139

This document is a preview generated by EVS

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 4-12: Data-link layer protocol specification – Type 12 elements

1 Scope

1.1 General

The data-link layer provides basic time-critical messaging communications between devices in an automation environment.

This protocol provides communication opportunities to all participating data-link entities

- a) in a synchronously-starting cyclic manner, and
- b) in a cyclic or acyclic asynchronous manner, as requested each cycle by each of those data-link entities.

Thus this protocol can be characterized as one which provides cyclic and acyclic access asynchronously but with a synchronous restart of each cycle.

1.2 Specifications

This standard specifies

- a) procedures for the transfer of data and control information from one data-link user entity to one or more user entity;
- b) the structure of the DLPDUs used for the transfer of data and control information by the protocol of this standard, and their representation as physical interface data units.

1.3 Procedures

The procedures are defined in terms of

- a) the interactions between DL-entities (DLEs) through the exchange of DLPDUs;
- b) the interactions between a DL-service (DLS) provider and a DLS-user in the same system through the exchange of DLS primitives;
- c) the interactions between a DLS-provider and the MAC services of ISO/IEC 8802-3.

1.4 Applicability

These procedures are applicable to instances of communication between systems which support time-critical communications services within the data-link layer of the OSI reference model, and which require the ability to interconnect in an open systems interconnection environment.

Profiles provide a simple multi-attribute means of summarizing an implementation's capabilities, and thus its applicability to various time-critical communications needs.

1.5 Conformance

This standard also specifies conformance requirements for systems implementing these procedures. This part of this standard does not contain tests to demonstrate compliance with such requirements.