

**Madalpingelised elektripaigaldised. Osa 7-701: Nõuded eripaigaldistele ja -paikadele. Vanne ja dušše sisaldavad ruumid**

**Low voltage electrical installations - Part 7-701:  
Requirements for special installations or locations -  
Locations containing a bath or shower**

## EESTI STANDARDI EESSÕNA

## NATIONAL FOREWORD

See Eesti standard EVS-HD 60364-7-701:2007+A11:2011 sisaldab Euroopa standardi HD 60364-7-701:2007+HD 60364-7-701:2007/A11:2011 ingliskeelset teksti.	This Estonian standard EVS-HD 60364-7-701:2007+A11:2011 consists of the English text of the European standard HD 60364-7-701:2007+HD 60364-7-701:2007/A11:2011.
Standard on jõustunud sellekohase teate avaldamisega EVS Teatajas.	This standard has been endorsed with a notification published in the official bulletin of the Estonian Centre for Standardisation.
Euroopa standardimisorganisatsioonid on teinud Euroopa standardi rahvuslikele liikmetele kättesaadavaks 23.02.2007.	Date of Availability of the European standard is 23.02.2007.
Standard on kättesaadav Eesti Standardikeskusest.	The standard is available from the Estonian Centre for Standardisation.

Tagasisidet standardi sisu kohta on võimalik edastada, kasutades EVS-i veebilehel asuvat tagasiside vormi või saates e-kirja meiliaadressile [standardiosakond@evs.ee](mailto:standardiosakond@evs.ee).

ICS 29.020, 91.140.50

Võtmesõnad: shower,

### Standardite reprodutseerimise ja levitamise õigus kuulub Eesti Standardikeskusele

Andmete paljundamine, taastekitamine, kopeerimine, salvestamine elektroonsesse süsteemi või edastamine ükskõik millises vormis või millisel teel ilma Eesti Standardikeskuse kirjaliku loata on keelatud.

Kui Teil on küsimusi standardite autorikaitse kohta, võtke palun ühendust Eesti Standardikeskusega:  
Aru 10, 10317 Tallinn, Eesti; [www.evs.ee](http://www.evs.ee); telefon 605 5050; e-post [info@evs.ee](mailto:info@evs.ee)

### The right to reproduce and distribute standards belongs to the Estonian Centre for Standardisation

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying, without a written permission from the Estonian Centre for Standardisation.

If you have any questions about copyright, please contact Estonian Centre for Standardisation:  
Aru 10, 10317 Tallinn, Estonia; [www.evs.ee](http://www.evs.ee); phone 605 5050; e-mail [info@evs.ee](mailto:info@evs.ee)

English version

**Low-voltage electrical installations –  
Part 7-701: Requirements for special installations or locations -  
Locations containing a bath or shower  
(IEC 60364-7-701:2006, modified)**

Installations électriques à basse tension –  
Partie 7-701: Règles pour les installations  
et emplacements spéciaux -  
Emplacements contenant une baignoire  
ou une douche  
(CEI 60364-7-701:2006, modifiée)

Errichten von Niederspannungsanlagen –  
Teil 7-701: Anforderungen  
für Betriebsstätten, Räume  
und Anlagen besonderer Art -  
Räume mit Badewanne oder Dusche  
(IEC 60364-7-701:2006, modifiziert)

This Harmonization Document was approved by CENELEC on 2006-09-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the Central Secretariat or to any CENELEC member.

This Harmonization Document exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: rue de Stassart 35, B - 1050 Brussels**

## Foreword

The text of document 64/1494/FDIS, future edition 2 of IEC 60364-7-701, prepared by IEC TC 64, Electrical installations and protection against electric shock, was submitted to the IEC-CENELEC parallel vote.

A draft amendment, prepared by SC 64A, Protection against electric shock, of Technical Committee CENELEC TC 64, Electrical installations and protection against electric shock, was submitted to the formal vote.

The combined texts were approved by CENELEC as HD 60364-7-701 on 2006-09-01.

The following dates were fixed:

- latest date by which the existence of the HD has to be announced at national level (doa) 2007-03-01
- latest date by which the HD has to be implemented at national level by publication of a harmonized national standard or by endorsement (dop) 2007-09-01
- latest date by which the national standards conflicting with the HD have to be withdrawn (dow) 2009-09-01

Annexes ZA and ZB have been added by CENELEC.

In this standard, the common modifications to the International Standard are indicated by a vertical line in the left margin of the text.

## **700.1 Introduction**

The requirements of this part of HD 60364 supplement, modify or replace certain of the general requirements of the other parts of HD 60364.

The clause numbering of Part 7-701 follows the pattern and corresponding references of HD 60364. The numbers following the particular number of Part 7-701 are those of the corresponding parts, or clauses of HD 60364.

The absence of reference to a part, a clause or a subclause means that the corresponding general requirements are applicable.

This document is a preview generated by EVS

## 701 Locations containing a bath or shower

### 701.1 Scope

The particular requirements of this part of HD 60364 apply to the electrical installations in locations containing a fixed bath (bath tub) or shower and to the surrounding zones as described in this standard.

This standard does not apply to emergency facilities, e.g. emergency showers used in industrial areas or laboratories.

NOTE 1 For locations containing a bath or shower for medical treatment, special requirements may be necessary.

NOTE 2 For prefabricated bath and/or shower units, see also EN 60335-2-105.

### 701.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

HD 60364-4-41:2007, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock* (IEC 60364-4-41:2005, modified)

HD 60364-5-54, *Low-voltage electrical installations – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements, protective conductors and protective bonding conductors* (IEC 60364-5-54, modified)

EN 61558-2-5, *Safety of power transformers, power supply units and similar – Part 2-5: Particular requirements for shaver transformers and shaver supply units* (IEC 61558-2-5)

### 701.30 Assessment of general characteristics

#### 701.30.1 General

When applying this standard, the zones specified in 701.30.2 to 701.30.4 shall be taken into account. For fixed prefabricated bath or shower units, the zones are applied to the situation when the bath or shower basin is in its usable configuration(s).

Horizontal or inclined ceilings, walls with or without windows, doors, floors and fixed partitions may limit the extent of locations containing a bath or shower as well as their zones. Where the dimensions of fixed partitions are smaller than the dimensions of the relevant zones, e.g. partitions having a height lower than 225 cm, the minimum distance in horizontal and vertical direction shall be taken into account ( see Figures 701.1 and 701.2 ).

For electrical equipment in parts of walls or ceilings limiting the zones specified in 701.30.2 to 701.30.4, but being part of the surface of that wall or ceiling, the requirements for the respective zone apply.

#### 701.30.2 Description of zone 0

Zone 0 is the interior of the bath tub or shower basin, see Figure 701.1.

For showers without basin, the height of zone 0 is 10 cm and its surface extent has the same horizontal extent as zone 1, see Figure 701.2.