
Fire detection and alarm systems —

Part 8:

**Carbon monoxide fire detectors using an
electro-chemical cell in combination
with a heat sensor**

Systèmes de détection et d'alarme d'incendie —

*Partie 8: Détecteurs de monoxyde de carbone pour la détection
d'incendie utilisant une cellule électrochimique en combinaison
avec un capteur de chaleur*



PDF disclaimer

This PDF file may contain embedded typefaces. In accordance with Adobe's licensing policy, this file may be printed or viewed but shall not be edited unless the typefaces which are embedded are licensed to and installed on the computer performing the editing. In downloading this file, parties accept therein the responsibility of not infringing Adobe's licensing policy. The ISO Central Secretariat accepts no liability in this area.

Adobe is a trademark of Adobe Systems Incorporated.

Details of the software products used to create this PDF file can be found in the General Info relative to the file; the PDF-creation parameters were optimized for printing. Every care has been taken to ensure that the file is suitable for use by ISO member bodies. In the unlikely event that a problem relating to it is found, please inform the Central Secretariat at the address given below.

This document is a preview generated by EVS



COPYRIGHT PROTECTED DOCUMENT

© ISO 2007

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword.....	v
Introduction.....	vii
1 Scope.....	1
2 Normative references.....	1
3 Definitions.....	2
4 General requirements.....	2
4.1 Compliance.....	2
4.2 Individual alarm indication.....	2
4.3 Connection of ancillary devices.....	2
4.4 Monitoring of detachable detectors.....	2
4.5 Manufacturer's adjustments.....	2
4.6 On-site adjustment of response behaviour.....	2
4.7 Rate-sensitive response behaviour.....	3
4.8 Marking.....	3
4.9 Data.....	4
4.10 Requirements for software controlled detectors.....	4
5 Tests.....	5
5.1 General.....	5
5.2 Repeatability of CO response.....	8
5.3 Directional dependence of CO response.....	8
5.4 Directional dependence of heat response.....	8
5.5 Lower limit of heat sensitivity.....	10
5.6 Reproducibility of CO response.....	10
5.7 Reproducibility of heat response.....	11
5.8 Exposure to chemical agents at environmental concentrations.....	11
5.9 Long-term stability of CO response.....	12
5.10 Saturation.....	12
5.11 Exposure to chemical agents that can be present during a fire.....	13
5.12 Variation in supply parameters.....	14
5.13 Air movement.....	15
5.14 Dry heat (operational).....	15
5.15 Cold (operational).....	16
5.16 Damp heat, cyclic (operational).....	17
5.17 Damp heat, steady state (endurance).....	18
5.18 Low humidity, steady state (endurance).....	19
5.19 Sulfur dioxide (SO ₂) corrosion (endurance).....	20
5.20 Shock (operational).....	21
5.21 Impact (operational).....	22
5.22 Vibration, sinusoidal (operational).....	23
5.23 Vibration, sinusoidal (endurance).....	24
5.24 Electromagnetic compatibility (EMC), immunity tests (operational).....	25
5.25 Fire sensitivity.....	26
6 Test report.....	28
Annex A (normative) Gas test chamber for response threshold value and cross sensitivity measurements.....	29
Annex B (normative) Heat tunnel for response time and response temperature measurements.....	30
Annex C (normative) Apparatus for impact test.....	31

Annex D (normative) Fire test room	33
Annex E (normative) Smouldering (pyrolysis) wood fire (TF2)	35
Annex F (normative) Glowing smouldering cotton fire (TF3)	38
Annex G (normative) Open plastics (polyurethane) fire (TF4).....	41
Annex H (normative) Liquid (heptane) fire (TF5).....	43
Annex I (normative) Deep-seated smouldering cotton fire (TF9)	45
Annex J (informative) Information concerning the construction of the gas test chamber.....	47
Annex K (informative) Construction of the heat tunnel.....	49

This document is a preview generated by EVS

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO 7240-8 was prepared by Technical Committee ISO/TC 21, *Equipment for fire protection and fire fighting*, Subcommittee SC 3, *Fire detection and alarm systems*.

ISO 7240 consists of the following parts, under the general title *Fire detection and alarm systems*:

- *Part 1: General and definitions*
- *Part 2: Control and indicating equipment*
- *Part 4: Power supply equipment*
- *Part 5: Point-type heat detectors*
- *Part 6: Carbon monoxide fire detectors using electro-chemical cells*
- *Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization*
- *Part 8: Carbon monoxide fire detectors using an electro-chemical cell in combination with a heat sensor*
- *Part 9: Test fires for fire detectors* [Technical Specification]
- *Part 10: Point-type flame detectors*
- *Part 11: Manual call points*
- *Part 12: Line type smoke detectors using a transmitted optical beam*
- *Part 13: Compatibility assessment of system components*
- *Part 14: Guidelines for drafting codes of practice for design, installation and use of fire detection and fire alarm systems in and around buildings* [Technical Report]
- *Part 15: Point type fire detectors using scattered light, transmitted light or ionization sensors in combination with a heat sensor*

- *Part 16: Sound system control and indicating equipment*
- *Part 19: Design, installation, commissioning and service of sound systems for emergency purposes*
- *Part 21: Routing equipment*
- *Part 22: Smoke-detection equipment for ducts*
- *Part 27: Point-type fire detectors using a scattered-light, transmitted-light or ionization smoke sensor, an electrochemical-cell carbon-monoxide sensor and a heat sensor*

Part 26, dealing with oil mist detectors, and Part 28, dealing with fire protection control equipment, are under development.

This document is a preview generated by EVS

Introduction

This part of ISO 7240 has been prepared by the Subcommittee ISO/TC 21/SC 3 and is based on both ISO 7240-5 for heat detectors and ISO 7240-6 for carbon monoxide fire detectors.

A fire detection and fire alarm system is required to function satisfactorily not only in the event of a fire, but also during and after exposure to conditions likely to be met in practice such as corrosion, vibration, direct impact, indirect shock and electromagnetic interference. Some tests specified are intended to assess the performance of the fire detectors under such conditions.

The performance of fire detectors is assessed from results obtained in specific tests; this part of ISO 7240 is not intended to place any other restrictions on the design and construction of such detectors.

Carbon monoxide (CO) fire detectors can react promptly to slow, smouldering fires involving carbonaceous materials. Although in the majority of fires the products of combustion are transported by convection, the gaseous nature of CO means that it also diffuses and, particularly in low energy fires, it can move ahead of the smoke plume and thus provide earlier detection.

CO fire detectors alone might not react quickly to flaming fires and the addition of a heat sensor as described in this part of ISO 7240 provides better detection to a broader spectrum of fires.

CO fire detectors based on electrochemical cells might be better suited to applications where smoke detectors can produce unwanted alarms due to the presence of dust, steam or cooking vapours, etc.

Whilst CO gas has greater mobility than smoke, it can be diluted by ventilation systems and be affected by convection currents. Hence, the same considerations as for point smoke detectors should be taken into account. Re-circulating systems confined to a single room have little effect on dilution, as this is similar to the natural diffusion of the CO gas.

It is important that the location of CO fire detectors take into account areas where false operation or non-operation is likely. Some typical locations where it is important to carefully evaluate the use of CO fire detectors are

- a) areas where CO gas can be present from exhausts and normal manufacturing processes;

EXAMPLES Car parks, car-park return air plenums, loading docks.

- b) confined areas where cigarette smoking is likely.

This document is a preview generated by EVS

Fire detection and alarm systems —

Part 8:

Carbon monoxide fire detectors using an electro-chemical cell in combination with a heat sensor

1 Scope

This part of ISO 7240 specifies requirements, test methods and performance criteria for point multi-sensor fire detectors that incorporate an electrochemical cell for sensing carbon monoxide (CO) in combination with one or more heat sensors, for use in fire detection and alarm systems installed in buildings (see ISO 7240-1).

For the testing of other types of CO multi-sensor fire detectors, or CO and heat multi-sensor fire detectors working on different principles, this part of ISO 7240 can be used for guidance. CO and heat multi-sensor fire detectors with special characteristics and developed for specific risks are not covered by this part of ISO 7240.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 209-1, *Wrought aluminium and aluminium alloys — Chemical composition and forms of products — Part 1: Chemical composition*

ISO 7240-1, *Fire detection and alarm systems — Part 1: General and definitions*

ISO 7240-5:2003, *Fire detection and alarm systems — Part 5: Point-type heat detectors*

ISO 7240-6, *Fire detection and alarm systems — Part 6: Carbon monoxide fire detectors using electro-chemical cells*

IEC 60068-1, *Environmental testing — Part 1: General and guidance*

IEC 60068-2-1, *Environmental testing — Part 2: Tests — Test A: Cold*

IEC 60068-2-2, *Environmental testing — Part 2: Tests — Test B: Dry heat*

IEC 60068-2-6, *Environmental testing — Part 2: Tests — Test Fc: Vibration (sinusoidal)*

IEC 60068-2-27, *Environmental testing — Part 2: Tests. Test Ea and guidance: Shock*

IEC 60068-2-30, *Environmental testing — Part 2-30: Tests — Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-42, *Environmental testing — Part 2-42: Tests — Test Kc: Sulphur dioxide test for contacts and connections*

IEC 60068-2-78, *Environmental testing — Part 2-78: Tests — Test Cab: Damp heat, steady state*

EN 50130-4, *Alarm Systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder and social alarm systems*